

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-1436:100 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Electronics Line USA, Inc., 1640 Range Street, Boulder, CO 80301
Contact: Scott M. Anderson (303) 938-1133

DESIGN: Model SUMMIT 3208 power limited household fire alarm control unit. Refer to listee's data sheet for additional detailed product description and operational consideration. System components:

3208	Control Unit
3106	LED Keypad
3108	LCD Keypad
Battery	12V, 6.5/7.0 Ah
Transformer	16.5V, 40 VA

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a residential fire alarm control unit for use with separately listed compatible initiating and indicating devices.

NOTE: Burglary and other non-fire functions not examined.

12-12-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 22, 2004

*Listing Expires **June 30, 2005***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager